



AUTOMATIC TANK GAUGE OPERATION INSPECTION

This procedure is to determine whether the automatic tank gauge (ATG) is operating properly. See PEI/RP1200-17, Section 8.2 for inspection procedures. This procedure is applicable to tank level monitor stems that touch the bottom of the tank when in place.

1. FACILITY INFORMATION					
Facility Name:	Phone Number:				
Address:	City:				
2. TESTER INFORMATION					
Name of Tester:	Name of Company:				
Address:	City:			State:	
Phone Number:	Email Address:				
3. ATG OPERATION INSPECTION					
Date of Test:					
Tank ID					
1. Tank Volume, gallons					
2. Tank Diameter, inches					
3. After removing the ATG from the tank, it has been inspected and any damaged or missing parts replaced?	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No
4. Float moves freely on the stem without binding?	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	□ Yes □ No
5. Fuel float level agrees with the value programmed into the console?	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No
6. Water float level agrees with the value programmed into the console?	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	□ Yes □ No
7. Inch level from bottom of stem when 90% alarm is triggered.					
8. Inch level at which the overfill alarm activates corresponds with value programmed in the gauge?	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No
Inch level from the bottom when the water float first triggers an alarm.					
Inch level at which the water float alarm activates corresponds with the value programmed in the gauge?	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No
Pass/Fail Criteria: If any answers to Lines 3, 4, 5 or 6 are "No," the system has failed the test.					
Test Results	☐ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail
Comments/Repairs/Retest:					